

INVITATION FOR BIDS

AUDITORIUM SEATING EQUIPMENT AND SUPPLIES BID #21-373

Seating Specification Irwin Seating Company

Model: 4.12.86.12 Citation

Part 1: General Specifications

1.01 Scope:

Deliver and install fixed upholstered chairs with upholstered seat and back, and aisle and center standards, all as specified, floor mounted, with self-lifting seat which raises automatically to a uniform 3/4 fold position.

1.02 ADA:

Comply with ADA (Americans with Disabilities Act) Rules and Regulations.

1.03 Sizes:

Varying lateral sizes of backs shall be used in accordance with approved seating plans, with standards in each row spaced laterally so that the end standards shall be in alignment from first to last row whether aisles are of constant or converging width.

1.04 Shop Drawings:

Submit a complete seating plan developed from the contract drawings, showing all chairs, sizes, and aisle widths. Assume complete responsibility for the accuracy of all chair measurements shown on the seating plan.

1.05 Examination & Acceptance of Work in Place:

Examine work in place on which seating work is dependent. Defects which may influence satisfactory completion and performance of seating work shall be corrected in accordance with the requirements of the applicable section of work prior to commencement of seating work.

1.06 Field Measurements:

Take field measurements to verify or supplement dimensions indicated. Be responsible for accurate fit of work.

1.07 Materials and Workmanship:

- a. Provide new materials of types specified.
- b. Turn over all work to the owner in undamaged condition.
- c. Provide workmanship of the best quality by craftsmen skilled in their respective trades.

1.08 Fire Performance Characteristics Of Upholstered Seating:

Chairs provided shall have been certified as meeting the flammability requirements of California Technical Bulletin No. 133, Flammability Test Procedure for Seating Furniture for Use in Public Occupancies, developed by the California Bureau of Home Furnishings and Thermal Insulation.

1.09 Quality Assurance:

To assure high and satisfactory quality, design, color and operation of products, reference has been made to brand names; however, it is not intended to limit competition and items of brands that are equal will be given full consideration.

Base Specification:

Specified
Irwin Seating Company

Fixed Chair
4.12.86.8 Citation

1.10 Responsibility of Bidder:

The bidder must provide the following with his bid:

Bidder shall submit a list of five (5) seating projects of similar size which have been in service for 5 years or longer. Projects submitted shall incorporate chairs with seats, backs and standards consistent with those offered on this project.

1.11 Delivery:

Deliver the seating at a proper time for installation that will not interfere with other trades operating in the building. Bid seating for installation and completion as directed by owner after that date.

1.12 Warranty:

- a. Provide a manufacturer's warranty covering the material and workmanship for a period of one year from date of final acceptance.
- b. Repair or replace any part which becomes defective during the warranty period, except where the product has been subject to accident, alterations, abuse, misuse or neglect.

Part 2: Material Specifications

2.01 Cast Iron:

Shall be Grey cast iron conforming to ASTM A48/A48M-03 Class 25 (25,000 PSI) minimum strength, and shall be free of blow holes and hot checks with parting lines ground smooth and shall be free of inordinately rough surfaces. Provide notarized certification that cast iron is 25,000 PSI tensile strength.

2.02 Steel:

All steel shall have smooth surfaces and be of sufficient gauge thickness and designed to withstand strains of normal use.

2.03 Wood:

All plywood shall be hardwood, hot press laminated using high frequency processes. Interior plies shall be Class 3 or better. All exposed, solid northern grown maple shall be clear and selected by color. Medium Density Fiberboard shall be resin bonded of wood particles, 5/8" minimum thickness, 45 lb./cu. ft. density.

2.04 Plastic Components:

- a. Injection molded structural plastic shall be one-piece, high impact resistant, 25% glass-filled polypropylene with built-in ultra-violet light inhibitors to retard fading.
- b. Injection molded decorative plastic shall be one-piece, high impact, linear polyethylene with built-in ultra-violet light inhibitors to retard fading.
- c. Plastic laminate shall be minimum 0.030 inch thickness, composed of a core of

kraft papers impregnated with phenolic resins, a decorative surface sheet, and overlay sheet containing melamine. Layers are fused together under pressures in excess of 1000 PSI, and temperatures over 275 degrees. Plastic laminate shall meet or exceed performance standards as established by N.E.M.A.

- d. Plastic shall have a maximum burn rate of 1" per minute when tested in accordance with ASTM D635, or Department of Transportation Motor Vehicle Safety Standard No. 302.

2.05 Padding Material:

Seat and back padding material shall be of new (prime manufacture) polyurethane foam. Padding material shall comply with the flammability requirements outlined in the California Technical Information Bulletin #117, Resilient Cellular Materials, Section A & D, dated February 1975, when tested in accordance with Federal Test Method Standard 191, Method 5903.2.

2.06 Fabric:

A specification for upholstered chairs is expected to contain a description of upholstery fabric required; otherwise the seating contractor must base a bid on their own choice. A wide variety of upholstery materials are available from a multitude of sources. Designer has great discretion in the fabric to be used. It is recommended that auditorium chair upholstery fabrics offer resistance to abrasion, stretch, seam failure when sewn, crocking, and allow finished chairs to have a reasonable cost. Further, it is required that fabric shall meet Class 1 flammability requirements of the U.S. Department of Commerce Commercial Standard 191-53 per Bulletin #117 (California Code).

2.07 Finish:

a. Metal Parts:

All exposed metal parts shall be powder coated with a hybrid thermosetting powder coat finish. The powder coat finish shall be applied by electrostatic means to a thickness of 2 - 5 mils, and shall provide a durable coating having a 2H Pencil hardness. Prior to powder coating, metal parts shall be treated with a three-stage bonderization process for superior finish adhesion, and after coating shall be oven baked to cause proper flow of the epoxy powder to result in a smooth, durable finish. Manufacturer's standard color range shall be used.

b. Wood Parts:

All exposed surfaces shall be stained to color selected and coated with lacquer of sufficient film depth to afford wear resistance of institutional quality and oven baked.

c. Plastic Parts:

Color of plastic shall be selected from manufacturer's standard color range.

d. Hardware:

All assembly hardware shall be rust resistant, black plated.

Part 3: Construction

3.01 Upholstered Chair Backs:

Backs shall be regular rectangular shaped, padded and upholstered on their face, with a one-piece injection molded plastic rear panel, and shall extend to a nominal 32" above finished floor. Structure of the back component shall be provided by a

7/16" thick, 5-ply hardwood inner panel, which shall serve as a foundation for the upholstery. The face of the back shall be upholstered over a 2 inch thick polyurethane foam pad. The polyfoam pad shall be securely cemented to the plywood inner panel and the upholstery fabric shall be securely fastened to the hardwood inner panel by means of upholstery staples to facilitate ease of re-upholstering. The outer panel shall be injection molded HDPE plastic, high impact-resistant, with textured outer surface, formed to enclose the edges of the inner upholstery panel at the top and both sides of the back, and shall be not less than 26" in length, extending below the seat level to protect the seat cushion. There shall be no exposed screws above the armrests. Back wings for attaching the back to the standards shall be not less than 14 gauge (.0747") steel, secured to the inner panel by though-bolting via four (4) machine screws and threaded steel washers. Back wings shall provide for 16 degree, 20 degree, or 24 degree pitch of back.

3.02 Upholstered Self-Lifting Seat:

Seats shall be padded and upholstered on their top surface with an ergonomically correct firm support system to provide exceptional comfort for the seated individual. Seat foundation shall be structural, injection molded polypropylene, and shall be quietly and automatically self-lifting to a 3/4 fold position when unoccupied. Seats shall be certified through routine testing during manufacturing to pass seat cycle oscillation, ASTM Designation F851-87 Test Method for Self-Rising Seat Mechanism, and 600 lb. static load to front of seat.

- a. The seat cushions shall have a base structure of properly contoured, rigid polypropylene, and shall have 3" thick individually molded polyurethane foam pads with the specified fabric, carefully tailored, and of panel-side construction, secured around the perimeter of the cushion frame by means of a drawstring and staples. Pads shall be individually molded, high resilient polyurethane foam conforming to the base structure on the bottom, and flat across the top, and shall have an extended, rounded front. The seat cushion assembly shall be securely locked to the seat foundation, preventing unauthorized removal; but facilitating convenient removal by trained maintenance personnel.
- b. Seat foundation shall be 25% glass-filled, injection molded polypropylene, strengthened by deep internal ribs and gussets, completely enclosing the self-lifting hinge mechanism, and providing an attractive, decorative bottom surface for the seat. Bolted attachment of the seat component to the chair structure shall be concealed by a color-coordinated plastic cap to present a finished, refined appearance. Bottom decorative surface shall be textured matching other plastic components in color.
- c. When unoccupied, the seat shall quietly and automatically rise to a 3/4 fold position, and upon a slight rearward pressure, shall achieve full-fold, allowing the patron additional passing room. The seat shall rotate on two, molded, structural, glass-filled nylon hinge rods in internally molded channels with integral downstops for exceptional strength. Seat-lift shall be accomplished by compression springs and lubricated plastic cams, providing quiet gentle seat uplift. Downstops and upstops shall be non-metallic, eliminating plangent noise and providing quiet operation.

3.03 Aisle and Center Standards

Aisle and center standards shall be modern pedestal-design, Class 25 cast gray iron, one-piece standards. Standards shall be cast to maintain proper seat and back height and angle. Standards shall be cast with front and rear flanges for extra strength. Mounting points for seats shall be designed with a reinforced area to

assure a solid fit, and shall be furnished with a cored bolt-hole to facilitate solid mounting through use of 5/16" x 1-3/4" hex bolts. Back attachment shall be arranged via 2 holes cast in the standard. Standards shall have integral cast lugs for mounting armrests.

- a. Aisle standards shall be fitted with decorator panels constructed of medium density fiberboard (MDF), surfaced with plastic laminate specified. The decorator panels shall be tapered-shape, approximately 11-1/2" wide, and shall be securely attached to the structural iron castings.
- b. Floor Mounting: Standards shall be cast to be compatible with the floor incline to maintain proper seat and back height and angle. Cast standards shall be provided with mounting feet featuring 4 anchoring holes allowing a choice of 2 alternative 2-hole anchoring schemes.

3.04 Armrests:

Armrests shall be solid hardwood with all edges well rounded. Armrests shall be furnished with two (2) keyhole slots in the bottom and shall lock securely to dovetail lugs provided on aisle and center standards. Further, one (1) security screw shall be utilized.

3.05 Handicapped Access Aisle Standards:

Aisle standards designated on the contract drawings shall be designed to allow an individual to transfer from a wheelchair to the theatre chair. The aisle standard support column shall be inclined toward the rear by approximately 16 degrees, and shall be equipped with an armrest capable of lifting to a position parallel with the chair back, opening sideways access to the seat. Aisle standards so equipped shall be provided with a label, displaying an easily recognizable "handicapped" symbol. Decorative requirements of aisle standards are waived for the handicapped access standards.

Part 4: Execution

4.01 Scope of Work:

The installation shall be performed by the successful bidder, under the direction of a capable installation superintendent, in a manner satisfactory to the architect, and the job turned over to the owner with all chairs complete and ready to use.

4.02 Method of Installation:

The seating plan shall be reproduced on the floor, all dimensions checked against the plan and necessary adjustments made in the layout for all discrepancies.

Chairs shall be attached by means of an approved style of wedge-type, zinc plated expansion anchors installed strictly according to the manufacturers' instructions. Floor mount chairs shall be attached with 1/4" expansion anchors by not less than 2-1/4" long. There shall be two (2) bolts per standard.

4.03 Cleaning:

Remove all debris caused by this work from the premises.